

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. S.H./2023 / 26

Date: 28 - 02 - 2023

It is certified that an inspection team headed by Dr Shailender Kumar ,Dy Civil surgeon, Gurugram and inspection done by Dr. Kanika, Nodal Officer School health , Gurugram of the **The Pine Crest , B-11, DLF-1, Gurugram** on **06-02-2023** and found that the, the **The Pine Crest , B-11, DLF-1, Gurugram** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.

Signature with Seal:

Name:

Designation:

[Handwritten Signature]
CIVIL SURGEON
GURUGRAM
[Date: 28/2/2023]

To

The Pine Crest,
B-11, DLF-1,
Gurugram

THE PINE CREST SCHOOL

[Handwritten Signature]
PRINCIPAL
AMITA DAHIYA

THE PINE CREST SCHOOL

[Handwritten Signature]
PRINCIPAL
AMITA DAHIYA

[Handwritten Signature]
MANAGER
THE PINE CREST SCHOOL
B-11, DLF-1
GURGAON, (HR)


Certificate of Analysis


Quality Standard	Parameters as desired
Issued to	- Pinecrest School, DLF City, Phase-1, Gurgaon
Kind attn.	- Mr.
Analysis no.	- 22070801


Nature of Sample	- Water Sample marked Drinking
Sample received on	- 8 th July 2022
Report Date	- 12 th July 2022
Analysis Dates	- 8 th July 2022 to 12 th July 2022
Sample receipt	- Picked by Lab
Sample Packing	- Sterilized and F'et Bottles

	PARAMETER	UNIT	RESULT	TEST METHOD	LIMITS	
					Desired	Permissible (in absence of alternate source)
General	Color	Hazen	05	IS 3025 Part 4	05	25
	Odor	Unit Less	Unobjectionable	IS 3025 Part 5	Unobjectionable	Unobjectionable
	Taste	Unit Less	Agreeable	IS 3025 Part 6	Agreeable	Agreeable
Bacteria	Coliform	CFU/100ml	Absent	IS1622	Absent	Absent
	E.Coli	CFU/100ml	Absent	IS1622	Absent	Absent
Physical	pH	Unit Less	7.80	IS 3025 Part 11	6.5-8.5	No Relaxation
	Conductivity	microS at 25°C	121	IS 3025 Part 14	...	-
	Turbidity	NTU	1.0	IS 3025 Part 10	5	10
	Total Dissolved Solids	mg/l	65	IS 3025 Part 16	500	2000
Chemical	M. Alkalinity as CaCO ₃	mg/l	31.5	IS 3025 Part 23	200	600
	Total Hardness as CaCO ₃	mg/l	34.8	IS 3025 Part 21	300	600
	Chlorides as Cl	mg/l	9.4	IS 3025 Part 32	250	1000
	Total Iron as Fe	mg/l	0.01	IS 3025 Part 53	0.3	1.0
	Residual Free Chlorine	mg/l	Nil	IS 3025 Part 35	0.20	-

Remarks: The no. of parameters tested is 14 only. The results indicate that the Quality of Water may be considered to be within the permissible limits for Drinking as per IS:10500, in regard to the parameters tested. The report is issued subject to the terms & conditions as mentioned overleaf.

Chemist
THE PINE CREST SCHOOL

PRINCIPAL
AMITA DAHIYA


MANAGER
THE PINE CREST SCHOOL
B-11, DLF-1
GURGAON, (HR)

THE PINE CREST SCHOOL

PRINCIPAL
AMITA DAHIYA
Authorized Signatory



QUALITY LAB is a trademark and fully owned unit of Quality Analyst & Labs Pvt. Ltd.
Office : 382, Vardhman Charve Plaza-5, Plot No. 20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088
Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA
Exclusive representatives in India for Sens Aqua, Naeringshagen No. 7340. OPPDAL, Norway
Exclusive representatives in india for Femko Technical Control and Certification Ltd., Izmir, Turkey for CE Marking